

ADDENDUM NO. 3

BID TITLE: Weston North Walking Nature Trail

BID NO: 2025-04

DATE: August 21, 2025

To All Bidders:

Bidders for the above referenced BID shall take note of the following changes, additions, deletions, clarifications, etc., to the BID documents, which shall become a part of and have precedence over anything shown or described otherwise.

A. CHANGES IN THE BID DOCUMENTS

None.

B. CLARIFICATIONS

None.

C. QUESTIONS FROM BIDDERS

- 1) Q: Upon our site visit, we found trees marked with numbers along the water's edge/existing tree line. There were no tree disposition plans provided. What do these numbers mean? Can you please clarify if any of these trees are to be removed, replaced, relocated, or root pruned?

A: No tree removal or relocation required for this project. Root pruning is required and provided for in bid line item #9.

- 2) Q: Weed Barrier. Please specify, as this is not detailed in the plans.

A: See Addendum #1, weed barrier not required.

- 3) Q: Bid Amounts Page – Item 4. The bid calls for furnishing and installing a 5-inch thick, 10-foot wide washed pea rock base.

A: See Addendum #2, Item 4 is 4" thick x 6' wide coquina/mortar mix.

- 4) Q: The plans/detail indicate a 6-inch thick, 8-foot wide limerock base (FDOT LBR 100). Please clarify which specification is correct

A: Item 5 – 6" thick limerock base. Plan shows 8' wide with total quantity of 75,000 SF in Bid Amounts.

5) Q: Item 5 (Picnic Table) Please provide further details.

A: Refer to Addendum #1 & 2.

6) Q: Additional Site Furniture (Sheet 11) Balance beam Robinia, Multi Timer Robinia, Dip bench Robinia, Sit-up bench Robinia, and Hurdles Robinia, (These are also not included on the bid amounts page.)

A: Refer to Addendums #1 & 2.

7) Q: Clean Fill & Bahia Sod. This item does not appear on the bid amounts page.

A: Refer to Addendums #1 & 2 (Bid Line Item #16).

8) Q: Erosion Control (Refer to Notes – Sheet 2) Hay bales, Silt fences, Turbidity barriers (These items are not listed on the bid amounts page.) The project engineer is to determine the specific areas for these measures. Can unit rate items for each control type be added to the bid amounts page? Factor in the Mobilization cost or will be paid by contingency?

A: See Addendum #2, Response #6.

9) Q: We understand that locations will be selected later during construction, but will there be any type of base for the equipment or stations like a concrete pad or just mulch?

A: No concrete pad will be ground mounted.

ATTACHMENTS

None.

END OF ADDENDUM NO. 3

All other information remains as originally described in the solicitation.